



PANVEL MUNICIPAL CORPORATION
Tal. Panvel, Dist. Raigad. Pin No. 410206



Office No- 27458040/41/42

Fire Office No- 27461500

Email-Panvelcorporation@gmail.com

Fax No- 022-27452233

Outword/No/Pmc/Fire/ 2121/Ref. No.460/E-2053750/2394220 /2026

Date- 29/07/2026

APPENDIX - VII

FIRE SAFETY CERTIFICATE

Certified that the M/S. DSP INTERNATIONAL SCHOOL at Plot No. 23, Sector-09, Kamothe, Navi Mumbai comprised of Ground + 5th Upper Floor owned / occupied by M/S. MAJI AAMDAR DATTUSHETH PATIL SHIKSHAN PRASARAK MANDAL's have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officer concerned of Fire Service on 23/07/2026 in the presence of Principal Mr. Vimmi Kapoor / Mr. Prakash Mhatre & M/s. S. B. Fire Safety Services, Fire License Agency and that the building/premises is fit for occupancy up to Class XII with effect from 23/07/2026 for a period of 1 Year in accordance with rule and subject to compliance of specific conditions as appended :-

- 1) In build Fire Fighting System Should be kept in good working condition all the time.
- 2) As per the Maharashtra Fire Prevention & Life Safety Act, 2006 it is statutory requirement to check the in-built fire protection system from licensing agency twice in a year (in the month of July & December) & produce the Form 'B' certificate to this department
- 3) School management shall trained all staff members to operate the Fire Extinguisher.

Issued on 23/07/2026 at Navi Mumbai by

Digitally signed by
Pravin Balu Bodkhe
Date: 29-07-2026

Signature with Seal : 12:51:23

Name : Pravin B. Bodkhe

Designation : Chief Fire Officer

Name & Address of Department / Office: Panvel Municipal Corporation


To,


Principal,

M/S. DSP INTERNATIONAL SCHOOL

M/S. MAJI AAMDAR DATTUSHETH PATIL SHIKSHAN PRASARAK MANDAL's

Plot No. 23, Sector-09, Kamothe, Navi Mumbai


Principal
DSP INTERNATIONAL SCHOOL


President
DSP INTERNATIONAL SCHOOL